CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Model SIGA-SEC2 Security Loop Module, KPDISP Control and Display Module, 24DC12 Bell Interface, GFD Ground Fault Detector, CRC/CRCXM Card Reader Interface, CRCRL Relay Module, CRCSND Card Reader Sounder and CRCXF Transformer. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12-24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed Models EST-3 fire alarm control units. (CSFM Listing No. 7165-1591:186 and 7170-1591:187)

NOTE: 1.   Model CRCXF Transformers may not be used for Fire application, Grade A Local mercantile, Grade A, B, or C Central Station, Grade A Proprietary, or hold-up alarm applications.

2.   Formerly 7300-1388:239

11-02-2002

Date Issued: **JANUARY 16, 2003**   *Listing Expires June 30, 2003*

A*uthorized By:*   **DIANE K. AREND**, *Senior Deputy*
Program Manager